



To: Mr. Nadir Kacar

Subject: Test results of 10x10 Exil

05.03.2013

The critical tests that represents the physical performance of our products are routinely carried out in our Process Control Laboratory. Our laboratory is regularly detected by TSE, the national standards institute of Turkey, directly refers to the European norms and CE committees. According to ISO 9001, all the test archives are available to anyone who desires to check the product quality.

Product	size	Average Length & Width	Thickns	Straight of sides	Surface flatness	Center curvature	Edge curvature	Warpage	Surface Quality	Water absorption	Strength	M.O.R.	Abrasion resistance	Crazing resistance
Exil Grey	10x10	97,4 x 97,4	6,7	< 0,1	< 0,1	< 0,1	< 0,1	< 0,1	First	1,95	1200	36,0	III	+
Exil White	10x10	97,3 x 97,3	6,7	< 0,1	< 0,1	< 0,1	< 0,1	< 0,1	First	1,81	1200	36,0	IV	+
Exil Black	10x10	97,3 x 97,3	6,8	< 0,1	< 0,1	< 0,1	< 0,1	< 0,1	First	1,83	1210	36,0	III	+
		(mm)	(mm)	(%)	(%)	(%)	(%)	(%)	(>%95)	(%)	(N)	(N/mm2)	(PEI)	(6 atm - 2 h)

Cem Caglar
Chief Quality Assurance